

Certificate of Compliance

Certificate: 1730466

Master Contract: 186833

Project: 1730466

Date Issued: November 3, 2005

Issued to: Coel Motori S.r.l.
Via Campania 36/38/40
I-20090 Fizzonasco di Pieve Emanuele (MI)
ITALY

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'

Issued by: G. Foulem



Authorized by: M.H.J. Hoendervangers



PRODUCTS

4211-01 - MOTORS AND GENERATORS

4211-81 - MOTORS AND GENERATORS - Certified for US Standard

Part A:

Squirrel-cage induction motors, 50-60 Hz, 2 through 12 poles, TEFC, with brake (ac or dc), with or without servo-ventilation, insulation Class F or H, horizontal or vertical, foot or flange mounting.

Series E, 3-phases, frame size, from 71 to 160 , 600 V max, 22.20 kW max.

Part B:

Squirrel-cage induction motors, 50-60 Hz, 2 through 12 poles, TEFC, with brake (dc), with or without servo-ventilation, insulation Class F or H, horizontal or vertical, foot or flange mounting.

Series FK, 3-phases, frame size, from 56 to 112 , 600 V max, 4.8 kW max.

Part :C

Squirrel-cage induction motors, 50-60 Hz, 2 through 12 poles, TEFC, with or without servo-ventilation, insulation Class F or H, horizontal or vertical, foot or flange mounting.

Series H, 3-phases, frame size, from 56 to 160 , 600V max, 22.20 kW max.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards 173046 November 3, 2001 86831730466